



Architecture | Engineering | Planning

1410 Rocky Ridge Drive, Suite 250  
Roseville, CA 95661  
(916) 787-5100 fax (916) 784-7738

---

# Clovis Community Medical Center

## RF 1363

## Structural Calculations



Commission No: 2088-052-01  
Sutter Clovis Community Medical Center  
Date: June 23, 2015

---

**CLOVIS – RF 1363**  
**HGA Commission Number 2088-052-01**

---

<b>TABLE OF CONTENTS</b>		<b>PAGES</b>
1	USGS SEISMIC OUTPUT	1
2	WALL STAND ANCHORAGE CALCULATION	2-4
3	GENERATOR CABINET ANCHORAGE CALCULATION	5-6
4	GRID HOLDER ANCHORAGE CALCULATION	7-8
5	COMPACT CONTAINER ANCHORAGE CALCULATION	9-11
6	BRIDGE & TUBE STAND ANCHORAGE CALCULATION	12-15
7	REMOTE TABLE ANCHORAGE CALCULATION	16-18
8	OSP-0086-10	19-22
9	HILTI KWIK BOLT CAPACITY	23-25

---

# USGS Design Maps Summary Report

## User-Specified Input


**Report Title** Clovis  
Wed June 17, 2015 16:42:38 UTC

**Building Code Reference Document** ASCE 7-10 Standard  
(which utilizes USGS hazard data available in 2008)

**Site Coordinates** 36.8392°N, 119.66°W

**Site Soil Classification** Site Class D - "Stiff Soil"



**Risk Category** IV (e.g. essential facilities)



## USGS-Provided Output

$S_s = 0.567 \text{ g}$	$S_{MS} = 0.763 \text{ g}$	$S_{DS} = 0.509 \text{ g}$
$S_1 = 0.238 \text{ g}$	$S_{M1} = 0.459 \text{ g}$	$S_{D1} = 0.306 \text{ g}$


For information on how the  $S_s$  and  $S_1$  values above have been calculated from probabilistic (risk-targeted) and deterministic ground motions in the direction of maximum horizontal response, please return to the application and select the "2009 NEHRP" building code reference document.



For  $PGA_M$ ,  $T_L$ ,  $C_{RS}$ , and  $C_{R1}$  values, please [view the detailed report](#).



**2013 CBC & ASCE 7-10 EQUIPMENT ANCHORAGE FORCES - WALL STAND - 3/A070**



- Height, H = -
- Height to center of gravity, Y = 42.0 in
- Length, L = 14.0 in
- Width, W = 10.0 in
- Overturning Dimension, ω = 10.0 in
  - x = 5.0 in
  - y = 7.0 in
- Weight, W<sub>p</sub> = 551 lbs
- # of anchors in shear = 4
- # of anchors in tension = 2
- Average roof height, h = 28 ft
- Height of component attachment with respect to grade, z = 0 ft

**Seismic**

Seismic design requirements for equipment are based on ASCE 7-10, Chapter 13.

**COMPONENT AMPLIFICATION FACTOR**

ASCE Section 13.5, 13.6 & ASCE Table 13.5-1, 13.6-1

$a_p = 1.0$

**COMPONENT RESPONSE MODIFICATION FACTOR**

ASCE Section 13.5, 13.6 & ASCE Table 13.5-1, 13.6-1

$R_p = 2.5$

**DESIGN SPECTRAL RESPONSE ACCELERATION**

CBC Section 1613A.5.4 & CBC Equation 16-39

$S_{DS} = 0.509$

**COMPONENT IMPORTANCE FACTOR**

ASCE Section 13.1.3

$I_p = 1.50$

**ATTACHMENT FACTOR IN CONCRETE OR MASONRY**

ASCE Section 13.4.2.1 and ACI 318-10 sec D3.3.4.3 d

$\Omega$  factor = 2.5

**SEISMIC DESIGN FORCE**

ASCE Section 13.3.1 & ASCE Equation 13.3-1

$F_p = 0.4a_p S_{DS} W_p / (R_p / I_p) (1 + 2z/h)$

$F_p = 0.122 W_p$

ASCE Section 13.3.1 & ASCE Equation 13.3-2

$F_{p,max} = 1.6 S_{DS} I_p W_p$

$F_{p,max} = 1.222 W_p$

ASCE Section 13.3.1 & ASCE Equation 13.3-3

$F_{p,min} = 0.3 S_{DS} I_p W_p$

$F_{p,min} = 0.229 W_p$

**SEISMIC DESIGN FORCES (ASD)**

ASCE Section 13.1.7 & 13.3.1

$F_{p,ASD} = 0.7(F_{p,govern})$

$F_{p,ASD} = 0.160 W_p$

ASCE Section 13.1.7 & 13.3.1

$F_{pv,ASD} = 0.7(0.2 S_{DS} W_p)$

$F_{p,v} = 0.071 W_p$

**DESIGN FORCES**

$F_{p,ASD} = 88$  lbs

OTM = Y \*  $F_{p,ASD} = 3710$  lb-in

$F_{p,v} = 39$  lbs

DLRM = (0.6W<sub>p</sub> - F<sub>pv</sub>) \* x = 0 lb-in

$T = \frac{(OTM - DLRM) * \Omega \text{ factor}}{\omega * (\# \text{ Anchors})}$

T = 464 lbs

$V = \frac{2 (F_{p,ASD} * (y / L)) * \Omega \text{ factor}}{\# \text{ Anchors}}$

V = 55 lbs

(V is approximate when number of anchors exceeds 4)

**USE (4)-1/2"Ø HILTI KB-TZ's W/ 2" EFFECTIVE EMBEDMENT**

T<sub>ALL</sub> = 1100 lbs

V<sub>ALL</sub> = 1342 lbs

UNITY CHECK = 0.46

## SIEMENS MEDICAL SOLUTION

**(AXIOM LUMINOS dRF SYSTEM)  
LUMINOS dRF WALL STAND WITH MOBILE DETECTOR**

DES. J. ROBERSON

JOB NO. 35-1326

DATE 1/20/14


SHEET

1

OF 2 SHEETS

SEISMIC ANCHORAGE

CONCRETE SLAB



$T_u = 2466 \text{ LB/BOLT (MAX)}$   
 $V_u = 372 \text{ LB/BOLT (MAX)}$

FRONT ELEVATION

NOTES:

- FORCES ARE DETERMINED PER 2013 CALIFORNIA BUILDING CODE AND ASCE 7-10. STRENGTH DESIGN IS USED.

HORIZONTAL FORCE ( $E_h$ ) =  $0.90 W_p$  ( $S_{ds} = 2.00$ ,  $a_p = 10$ ,  $I_p = 15$ ,  $R_p = 15$ ,  $\Omega_o = 1.5$ ,  $z/h = 0$ )  
HORIZONTAL FORCE ( $E_{hc}$ ) =  $1.35 W_p$  ( $\Omega_o = 1.5$  FOR CONCRETE ANCHORAGE)  
VERTICAL FORCE ( $E_v$ ) =  $0.40 W_p$

- CENTER OF GRAVITY (C.G.) AND WEIGHT ARE THE GOVERNING PARAMETERS FOR DESIGN. THESE CALCULATIONS ENCOMPASS ALL WEIGHTS UP TO THE MAXIMUM WEIGHT SHOWN.
- STRUCTURAL ENGINEER OF RECORD FOR THE BUILDING SHALL PROVIDE SUPPORT STRUCTURE DESIGNED TO SUPPORT WEIGHTS AND FORCES SHOWN, IN COMBINATION WITH ALL OTHER LOADS THAT MAY BE PRESENT.



## SIEMENS MEDICAL SOLUTION

DES. J. ROBERSON

SHEET

2

JOB NO. 35-1326

OF 2 SHEETS


**(AXIOM LUMINOS dRF SYSTEM)  
LUMINOS dRF WALL STAND WITH MOBILE DETECTOR**

DATE 1/20/14

SEISMIC ANCHORAGE

CONCRETE SLAB

C.G. WT. = 551 LB  
( $\bar{r} = 42"$ )



USE 4- 1/2"  $\phi$  HILTI KB-TZ  
EXPANSION ANCHORS  
(MIN. EMBED. ( $h_{ea}$ ) = 3-1/4")

PLAN AT BASE

LOADS: PER 2013 CALIFORNIA BUILDING CODE AND ASCE 7-10.

(STRENGTH DESIGN IS USED) ( $S_{ds} = 2.00$ ,  $a_p = 1.0$ ,  $I_p = 15$ ,  $R_p = 15$ ,  $\Omega_o = 15$ ,  $z/h = 0$ )

WEIGHT = 551 LB

HORIZONTAL FORCE ( $E_{hd}$ ) = 135  $W_p = 744$  LB

VERTICAL FORCE ( $E_v$ ) = 0.40  $W_p = 220$  LB

BOLT FORCES:

BOLT SPEC: 1/2"  $\phi$  HILTI KB-TZ:

$\phi T = 0.75 \phi N_n = 2625$  LB/BOLT (TENSION)

$\phi V = \phi V_n = 3572$  LB/BOLT (SHEAR)

TENSION (T)

$$T_{u \text{ MAXIMUM}} = \left[ \frac{744\#(42")}{2 \text{ BOLTS}(10.1")} \times (0.3) \right] + \frac{744\#(42")}{1 \text{ BOLT}(14.6")} - \frac{(0.9(551\#) - 220\#)}{2 \text{ BOLTS}} = 2466 \text{ LB/BOLT (MAX)}$$

(HORIZ. - SIDE TO SIDE)    (HORIZ. - FRONT TO BACK)    (0.9(WEIGHT) -  $E_v$ )

SHEAR (V)

$$V_{u \text{ MAXIMUM}} = \frac{744\#}{2 \text{ BOLTS}} = 372 \text{ LB/BOLT (MAX)}$$

UNITY CHECK:


$$\left( \frac{T_u}{\phi T} \right) + \left( \frac{V_u}{\phi V} \right) \leq 1.2 \left( \frac{2466}{2625} \right) + \left( \frac{372}{3572} \right) = 1.04 \leq 1.2 \therefore \text{OK}$$

NOTE:

STRUCTURAL ENGINEER OF RECORD SHALL PROVIDE SLAB OR OTHER SUPPORT STRUCTURE TO SUPPORT WEIGHTS AND FORCES SHOWN.



**2013 CBC & ASCE 7-10 EQUIPMENT ANCHORAGE FORCES - GENERATOR CABINET - 4/A070**



- Height, H = -
- Height to center of gravity, Y = -
- Length, L = -
- Width, W = -
- Overturning Dimension, ω = -
- x = -
- y = -
- Weight, W<sub>p</sub> = 838 lbs
- # of anchors in shear = -
- # of anchors in tension = -
- Average roof height, h = 28 ft
- Height of component attachment with respect to grade, z = 4 ft

**Seismic**

Seismic design requirements for equipment are based on ASCE 7-10, Chapter 13.

**COMPONENT AMPLIFICATION FACTOR**

ASCE Section 13.5, 13.6 & ASCE Table 13.5-1, 13.6-1

$a_p = 1.0$

**COMPONENT RESPONSE MODIFICATION FACTOR**

ASCE Section 13.5, 13.6 & ASCE Table 13.5-1, 13.6-1

$R_p = 2.5$

**DESIGN SPECTRAL RESPONSE ACCELERATION**

CBC Section 1613A.5.4 & CBC Equation 16-39

$S_{DS} = 0.509$

**COMPONENT IMPORTANCE FACTOR**

ASCE Section 13.1.3

$I_p = 1.50$

**ATTACHMENT FACTOR IN CONCRETE OR MASONRY**

ASCE Section 13.4.2.1 and ACI 318-10 sec D3.3.4.3 d

$\Omega$  factor = 1.0 *← 2.5 for KB-72*

**SEISMIC DESIGN FORCE**

ASCE Section 13.3.1 & ASCE Equation 13.3-1

$F_p = 0.4a_p S_{DS} W_p / (R_p / I_p) (1 + 2z/h)$

$F_p = 0.157 W_p$

ASCE Section 13.3.1 & ASCE Equation 13.3-2

$F_{p,max} = 1.6 S_{DS} I_p W_p$

$F_{p,max} = 1.222 W_p$

ASCE Section 13.3.1 & ASCE Equation 13.3-3

$F_{p,min} = 0.3 S_{DS} I_p W_p$

$F_{p,min} = 0.229 W_p$

**SEISMIC DESIGN FORCES (ASD)**

ASCE Section 13.1.7 & 13.3.1

$F_{p,ASD} = 0.7 (F_{p,govern})$

$F_{p,ASD} = 0.160 W_p$

ASCE Section 13.1.7 & 13.3.1

$F_{pv,ASD} = 0.7 (0.2 S_{DS} W_p)$

$F_{p,v} = 0.071 W_p$

**DESIGN FORCES**

$F_{p,ASD} = 134 \text{ lbs}$

$F_{p,v} = 60 \text{ lbs}$

*Handwritten calculations:*  
 $T_{SMS} = 0.3 \left( \frac{134 \text{ lbs} (8 \text{ ft}) (42.3 \text{ ft})}{2 \text{ screws} (27.5 \text{ ft}) (86.75 \text{ ft})} \right) + \frac{134 \text{ lbs} (42.3 \text{ ft})}{4 \text{ screws} (86.75 \text{ ft})} = 19 \text{ lbs (SMS)}$   
 $V_{SMS} = \frac{134 \text{ lbs} (42.3 \text{ ft})}{4 \text{ screws} (86.75 \text{ ft})}$   
 $V_{LIFT} = \frac{134 \text{ lbs} (43.5 \text{ ft}) (2.5)}{2 \text{ lifts} (86.75 \text{ ft})} = 16 \text{ lbs (SMS)}$   
 $V = 84 \text{ lbs (B.M.)}$

USE (2) #10 SMS to 16GA Track Backing at Each Clip

- T<sub>ALL</sub> = 159 lbs
- V<sub>ALL</sub> = 140 lbs
- UNITY CHECK = 0.23

USE (2) 3/8" Ø HILTI KB-TZ's W/ 2" EFF. EMBED.

- T<sub>ALL</sub> = 1039 lbs
- V<sub>ALL</sub> = 1098 lbs
- UNITY CHECK = 0.08

## SIEMENS MEDICAL SOLUTIONS

(AXIOM LUMINOS dRF SYSTEM)

### POLYDOROS F65 65kw-80kw GENERATOR CABINET

DES. J. ROBERSON

JOB NO. 35-1326

DATE 1/16/14

SHEET

1


OF 1

SHEETS

SEISMIC ANCHORAGE

CONCRETE SLAB / CONCRETE SLAB ON METAL DECK

BRACKET SUPPLIED BY CONTRACTOR



FRONT ELEVATION


4 3 X 3 X 1/4" X 2"  
W/3- #12 TEK SCREWS TO  
CABINET & TO BACKING  
PLATE (2 PLACES)

STRUCTURAL ENGINEER OF RECORD  
SHALL DESIGN THE BACKING  
PLATE (16 GA., 50 KSI MIN.)  
AND THE WALL STRUCTURE

USE 2- 3/8"  $\phi$  SIMPSON  
STRONG BOLT 2  
EXPANSION ANCHOR  
(MIN. EMBED. = 1.875")  
(EFF EMBED. ( $h_{ef}$ ) = 1.5")

AT CONCRETE SLAB  
NORMAL WEIGHT CONCRETE  
CONC. (3000 PSI MIN.)

OR  
AT CONCRETE SLAB ON METAL DECK  
N.W. OR SAND L.W.  
( $f'_c$  = 3000 PSI MIN.)



SIDE ELEVATION

LOADS: PER 2013 CALIFORNIA BUILDING CODE AND ASCE 7-10.

(STRENGTH DESIGN IS USED) ( $S_{Ds} = 2.5$ ,  $a_p = 1.0$ ,  $I_p = 1.5$ ,  $R_p = 2.5$ ,  $\Omega_e = 2.5$ ,  $z/h \leq 1$ )

WEIGHT = 838 LB

HORIZONTAL FORCE ( $E_h$ ) = 1.80  $W_p = 1508$  LB

HORIZONTAL FORCE ( $E_{hc}$ ) = 4.50  $W_p = 3771$  LB

VERTICAL FORCE ( $E_v$ ) = 0.50  $W_p = 419$  LB

BOLT FORCES:

TENSION (T)

$$T_{u \text{ PARALLEL}} = \frac{1508 \# (8'') (42.3'')}{3 \text{ SCREWS } (27.5'') (85.6'')} = 72 \text{ LB}$$

$$T_{u \text{ PERR.}} = \frac{1508 \# (42.3'')}{6 \text{ SCREWS } (85.6'')} = 124 \text{ LB}$$

$$T_{u \text{ MAX}} = (0.3)(72 \#) + 124 \# = 146 \text{ LB/SCREW (MAX)}$$

SHEAR (V)

$$V_{u \text{ WALL}} = \frac{1508 \# (42.3'')}{6 \text{ SCREWS } (85.6'')} = 124 \text{ LB/SCREW (MAX)}$$

$$V_{u \text{ FLOOR}} = \frac{3771 \# (43.3'')}{2 \text{ BOLTS } (85.6'')} = 954 \text{ LB/BOLT (MAX)}$$

#12 TEK SCREWS TO 16 GAGE, 50 KSI

$\phi T = 328$  LB/SCREW

$\phi V = 288$  LB/SCREW

UNITY CHECK:

$$\left( \frac{T_u}{\phi T} \right) + \left( \frac{V_u}{\phi V} \right) \leq 1.0$$


$$\left( \frac{146}{328} \right) + \left( \frac{124}{288} \right) = 0.88 \leq 1.0 \therefore \text{O.K.}$$

BOLT SPECS: 3/8"  $\phi$  SIMPSON STRONG BOLT 2  
 $\phi V = 1170$  LB/BOLT (SHEAR)





**2013 CBC & ASCE 7-10 EQUIPMENT ANCHORAGE FORCES - GRID HOLDER - 6/A070**



- Height, H = -
- Height to center of gravity, Y = -
- Length, L = -
- Width, W = -
- Overturning Dimension, ω = -
- x = -
- y = -
- Weight,  $W_p = 50$  lbs
- # of anchors in shear = -
- # of anchors in tension = -
- Average roof height, h = 28 ft
- Height of component attachment with respect to grade, z = 6 ft

**Seismic**

Seismic design requirements for equipment are based on ASCE 7-10, Chapter 13.

**COMPONENT AMPLIFICATION FACTOR**

ASCE Section 13.5, 13.6 & ASCE Table 13.5-1, 13.6-1

$a_p = 1.0$

**COMPONENT RESPONSE MODIFICATION FACTOR**

ASCE Section 13.5, 13.6 & ASCE Table 13.5-1, 13.6-1

$R_p = 2.5$

**DESIGN SPECTRAL RESPONSE ACCELERATION**

CBC Section 1613A.5.4 & CBC Equation 16-39

$S_{DS} = 0.509$

**COMPONENT IMPORTANCE FACTOR**

ASCE Section 13.1.3

$I_p = 1.50$

**ATTACHMENT FACTOR IN CONCRETE OR MASONRY**

ASCE Section 13.4.2.1 and ACI 318-10 sec D3.3.4.3 d

$\Omega$  factor = 1.0

**SEISMIC DESIGN FORCE**

ASCE Section 13.3.1 & ASCE Equation 13.3-1

$F_p = 0.4a_p S_{DS} W_p / (R_p / I_p) (1 + 2z/h)$

$F_p = 0.175 W_p$

ASCE Section 13.3.1 & ASCE Equation 13.3-2

$F_{p,max} = 1.6 S_{DS} I_p W_p$

$F_{p,max} = 1.222 W_p$

ASCE Section 13.3.1 & ASCE Equation 13.3-3

$F_{p,min} = 0.3 S_{DS} I_p W_p$

$F_{p,min} = 0.229 W_p$

**SEISMIC DESIGN FORCES (ASD)**

ASCE Section 13.1.7 & 13.3.1

$F_{p,ASD} = 0.7(F_{p,govern})$   
 $F_{pv,ASD} = 0.7(0.2 S_{DS} W_p)$

$F_{p,ASD} = 0.160 W_p$

ASCE Section 13.1.7 & 13.3.1

$F_{p,v} = 0.071 W_p$

**DESIGN FORCES**

$F_{p,ASD} = 8$  lbs

$F_{p,v} = 4$  lbs

$T = \frac{(50^* + 4^*) 4^*}{2 \text{ SCREWS } (13.1^*)} + 0.3 \left( \frac{8^* (4^*)}{15 \text{ NUTS } (14^*)} + \frac{5^*}{25 \text{ NUTS}} \right)$

$T = 13$  lbs

$V = \frac{50^* + 8^* + 4^*}{2 \text{ SCREWS}}$

$V = 31$  lbs

**USE (2)-#12 SMS to 16GA Track Backing**

$T_{ALL} = 205$  lbs

$V_{ALL} = 180$  lbs

UNITY CHECK = 0.24

## SIEMENS MEDICAL SOLUTION

### AXIOM LUMINOS dRF SYSTEM GRID HOLDER

DES. **J. ROBERSON**

JOB NO. **35-1326**

DATE **1/16/14**

SHEET


**1**

OF **1**

SHEETS

SEISMIC ANCHORAGE

WALL MOUNTED




FRONT ELEVATION

STRUCTURAL ENGINEER OF RECORD SHALL DESIGN THE BACKING PLATE (16 GA. 50 KSI MIN.) AND THE WALL STRUCTURE

USE (2) #12 TEK SCREWS TO BACKING PLATE OR DIRECTLY TO STEEL STUDS

$T_u = 66$  LB/SCREW (MAX)  
 $V_u = 88$  LB/SCREW (MAX)



SIDE ELEVATION

LOADS: PER 2013 CALIFORNIA BUILDING CODE AND ASCE 7-10.

(STRENGTH DESIGN IS USED) ( $S_{ds} = 2.5$ ,  $a_p = 10$ ,  $I_p = 1.5$ ,  $R_p = 2.5$ ,  $z/h \leq 1$ )

WEIGHT = 50 LB

HORIZONTAL FORCE ( $E_h$ ) =  $180 W_p = 90$  LB

VERTICAL FORCE ( $E_v$ ) =  $0.50 W_p = 25$  LB

BOLT FORCES:

TENSION (T)

$$T_{u \text{ VERTICAL}} = \frac{(50\#(1.2) + 25\#)4''}{2 \text{ SCREWS } (13.1'')} = 13 \text{ LB/SCREW}$$

$$T_{u \text{ PARALLEL}} = \frac{90\#(4'')}{1 \text{ SCREW } (14'')} = 26 \text{ LB/SCREW}$$

$$T_{u \text{ PERP.}} = \frac{90\#}{2 \text{ SCREWS}} = 45 \text{ LB/SCREW}$$

$$T_{u \text{ MAX}} = 13\# + (0.3)(26\#) + 45\# = 66 \text{ LB/SCREW (MAX)}$$

SHEAR (V)

$$V_{u \text{ MAX}} = \frac{50\#(1.2) + 25\# + 90\#}{2 \text{ SCREWS}} = 88 \text{ LB/SCREW (MAX)}$$

#12 TEK SCREWS TO 16 GAGE, 50 KSI

$\phi T = 328$  LB/SCREW

$\phi V = 288$  LB/SCREW

UNITY CHECK:

$$\left( \frac{T_u}{\phi T} \right) + \left( \frac{V_u}{\phi V} \right) \leq 1.0$$

$$\left( \frac{66}{328} \right) + \left( \frac{88}{288} \right) = 0.51 \leq 1.0 \therefore \text{OK}$$


NOTE:

STRUCTURAL ENGINEER OF RECORD SHALL PROVIDE RIGID ( $a_p = 1.0$ ) SUPPORT STRUCTURE TO SUPPORT WEIGHTS AND FORCES SHOWN IN COMBINATION WITH ALL OTHER LOADS THAT MAY BE PRESENT.





**2013 CBC & ASCE 7-10 EQUIPMENT ANCHORAGE FORCES - COMPACT CONTAINER - 7/A070**



- Height, H = 23.0 in
- Height to center of gravity, Y = 11.5 in
- Length, L = 30.0 in
- Width, W = 15.0 in
- Overturning Dimension, ω = 15.0 in
  - x = 7.5 in
  - y = 15.0 in
- Weight, W<sub>p</sub> = 110 lbs
- # of anchors in shear = 4
- # of anchors in tension = 2
- Average roof height, h = 28 ft
- Height of component attachment with respect to grade, z = 0 ft

**Seismic**

Seismic design requirements for equipment are based on ASCE 7-10, Chapter 13.

**COMPONENT AMPLIFICATION FACTOR**

ASCE Section 13.5, 13.6 & ASCE Table 13.5-1, 13.6-1

$a_p = 2.5$

**COMPONENT RESPONSE MODIFICATION FACTOR**

ASCE Section 13.5, 13.6 & ASCE Table 13.5-1, 13.6-1

$R_p = 6.0$

**DESIGN SPECTRAL RESPONSE ACCELERATION**

CBC Section 1613A.5.4 & CBC Equation 16-39

$S_{DS} = 0.509$

**COMPONENT IMPORTANCE FACTOR**

ASCE Section 13.1.3

$I_p = 1.50$

**ATTACHMENT FACTOR IN CONCRETE OR MASONRY**

ASCE Section 13.4.2.1 and ACI 318-10 sec D3.3.4.3 d

$\Omega \text{ factor} = 2.5$

**SEISMIC DESIGN FORCE**

ASCE Section 13.3.1 & ASCE Equation 13.3-1

$F_p = 0.4a_p S_{DS} W_p / (R_p / I_p) (1 + 2z/h)$

$F_p = 0.127 W_p$

ASCE Section 13.3.1 & ASCE Equation 13.3-2

$F_{p,max} = 1.6 S_{DS} I_p W_p$

$F_{p,max} = 1.222 W_p$

ASCE Section 13.3.1 & ASCE Equation 13.3-3

$F_{p,min} = 0.3 S_{DS} I_p W_p$

$F_{p,min} = 0.229 W_p$

**SEISMIC DESIGN FORCES (ASD)**

ASCE Section 13.1.7 & 13.3.1

$F_{p,ASD} = 0.7 (F_{p,govern})$

$F_{p,ASD} = 0.160 W_p$

ASCE Section 13.1.7 & 13.3.1

$F_{pv,ASD} = 0.7 (0.2 S_{DS} W_p)$

$F_{p,v} = 0.071 W_p$

**DESIGN FORCES**

$F_{p,ASD} = 18 \text{ lbs}$

$OTM = Y * F_{p,ASD} = 203 \text{ lb-in}$

$F_{p,v} = 8 \text{ lbs}$

$DLRM = (0.6 W_p - F_{pv}) * x = 436 \text{ lb-in}$

$T = \frac{(OTM - DLRM) * \Omega \text{ factor}}{\omega * (\# \text{ Anchors})}$

T = None

$V = \frac{2 (F_{p,ASD} * (y / L)) * \Omega \text{ factor}}{\# \text{ Anchors}}$

V = 11 lbs

(V is approximate when number of anchors exceeds 4)

**USE (4)-3/8"Ø HILTI KB-TZ's W/ 2" EFFECTIVE EMBEDMENT**

$T_{ALL} = 1039 \text{ lbs}$

$V_{ALL} = 1098 \text{ lbs}$

UNITY CHECK = 0.01



# SIEMENS MEDICAL SOLUTIONS

(AXIOM LUMINOS dRF SYSTEM)

## FLUOROSPOT COMPACT CONTAINER

DES. J. ROBERSON

JOB NO. 35-1326

DATE 1/20/14


SHEET

1

OF 2 SHEETS

SEISMIC ANCHORAGE

CONCRETE SLAB/CONCRETE SLAB ON METAL DECK



T<sub>u</sub> = 215 LB/BOLT (MAX)  
V<sub>u</sub> = 259 LB/BOLT (MAX)

### NOTES:

- FORCES ARE DETERMINED PER 2013 CALIFORNIA BUILDING CODE AND ASCE 7-10. STRENGTH DESIGN IS USED.

HORIZONTAL FORCE (E<sub>h</sub>) = 1.88 W<sub>p</sub> (S<sub>ds</sub> = 2.5, a<sub>p</sub> = 2.5, I<sub>p</sub> = 1.5, R<sub>p</sub> = 6.0, Ω<sub>o</sub> = 2.5, z/h ≤ 1)  
 HORIZONTAL FORCE (E<sub>hc</sub>) = 4.70 W<sub>p</sub> (Ω<sub>o</sub> = 2.5 FOR CONCRETE ANCHORAGE)  
 VERTICAL FORCE (E<sub>v</sub>) = 0.50 W<sub>p</sub>

- CENTER OF GRAVITY (C.G.) AND WEIGHT ARE THE GOVERNING PARAMETERS FOR DESIGN. THESE CALCULATIONS ENCOMPASS ALL WEIGHTS UP TO THE MAXIMUM WEIGHT SHOWN.
- STRUCTURAL ENGINEER OF RECORD FOR THE BUILDING SHALL PROVIDE SUPPORT STRUCTURE DESIGNED TO SUPPORT WEIGHTS AND FORCES SHOWN, IN COMBINATION WITH ALL OTHER LOADS THAT MAY BE PRESENT.



## SIEMENS MEDICAL SOLUTIONS

DES. J. ROBERSON

SHEET

2

(AXIOM LUMINOS dRF SYSTEM)

JOB NO. 35-1326

## FLUOROSPOT COMPACT CONTAINER


DATE 1/20/14

OF 2 SHEETS

SEISMIC ANCHORAGE

CONCRETE SLAB/CONCRETE SLAB ON METAL DECK

NOTE: FIT CORNER BRACKETS  
SNUGLY AGAINST CABINET.  
PROVIDE METAL SHIMS AS  
REQUIRED.




C.G. WT. = 110 LB

USE 4- 3/8" SIMPSON  
STRONG BOLT 2  
EXPANSION ANCHORS  
(MIN EMBED = 1.875")  
(EFF EMBED (net) = 1.5")

BRACKET (SUPPLIED  
BY CONTRACTOR)

PLAN AT BASE



CORNER BRACKET

LOADS: PER 2013 CALIFORNIA BUILDING CODE AND ASCE 7-10.

(STRENGTH DESIGN IS USED) ( $S_{ds} = 2.5$ ,  $a_p = 2.5$ ,  $I_p = 15$ ,  $R_p = 6.0$ ,  $\Omega_0 = 2.5$ ,  $z/h \leq 1$ )

WEIGHT = 110 LB

HORIZONTAL FORCE ( $E_{hd}$ ) =  $4.70 W_p = 517$  LB

VERTICAL FORCE ( $E_v$ ) =  $0.50 W_p = 55$  LB

BOLT FORCES:

TENSION (T)

$$T_{u \text{ MAXIMUM}} = \left[ \frac{517\#(11.5'')}{2 \text{ BOLTS}(29.5'')} \times (0.3) \right] + \frac{517\#(11.5'')}{2 \text{ BOLTS}(15.2'')} - \frac{(0.9(110\#) - 55\#)}{4 \text{ BOLTS}} = 215 \text{ LB/BOLT (MAX)}$$

( HORIZ. - SIDE TO SIDE )      ( HORIZ. - FRONT TO BACK )      ( 0.9(WEIGHT) -  $E_v$  )

SHEAR (V)

$$V_{u \text{ MAXIMUM}} = \frac{517\#}{2 \text{ BOLTS}} = 259 \text{ LB/BOLT (MAX)}$$

UNITY CHECK:

$$\left( \frac{T_u}{\phi T} \right) + \left( \frac{V_u}{\phi V} \right) \leq 1.2 \quad \left( \frac{215}{417} \right) + \left( \frac{259}{1170} \right) = 0.74 \leq 1.2 \quad \therefore \text{O.K.}$$

BOLT SPECS: 3/8"  $\phi$  SIMPSON STRONG BOLT 2

$\phi V = 417$  LB/BOLT (TENSION)


$\phi V = 1170$  LB/BOLT (SHEAR)

NOTE:

STRUCTURAL ENGINEER OF RECORD SHALL PROVIDE SLAB OR OTHER SUPPORT STRUCTURE TO SUPPORT WEIGHTS AND FORCES SHOWN IN COMBINATION WITH ALL OTHER LOADS THAT MAY BE PRESENT.



**2013 CBC & ASCE 7-10 EQUIPMENT ANCHORAGE FORCES - BRIDGE & TUBE STAND - 8/A070**



- Height, H = -
- Height to center of gravity, Y = -
- Length, L = -
- Width, W = -
- Overturning Dimension, ω = -
- x = -
- y = -
- Weight, W<sub>p</sub> = -
- # of anchors in shear = -
- # of anchors in tension = -
- Average roof height, h = 28 ft
- Height of component attachment with respect to grade, z = 10 ft

**Seismic**

Seismic design requirements for equipment are based on ASCE 7-10, Chapter 13.

**COMPONENT AMPLIFICATION FACTOR**

ASCE Section 13.5, 13.6 & ASCE Table 13.5-1, 13.6-1

$a_p = 2.5$

**COMPONENT RESPONSE MODIFICATION FACTOR**

ASCE Section 13.5, 13.6 & ASCE Table 13.5-1, 13.6-1

$R_p = 2.5$

**DESIGN SPECTRAL RESPONSE ACCELERATION**

CBC Section 1613A.5.4 & CBC Equation 16-39

$S_{DS} = 0.509$

**COMPONENT IMPORTANCE FACTOR**

ASCE Section 13.1.3

$I_p = 1.50$

**ATTACHMENT FACTOR IN CONCRETE OR MASONRY**

ASCE Section 13.4.2.1 and ACI 318-10 sec D3.3.4.3 d

$\Omega \text{ factor} = 1.0$

**SEISMIC DESIGN FORCE**

ASCE Section 13.3.1 & ASCE Equation 13.3-1

$F_p = 0.4a_p S_{DS} W_p / (R_p / I_p) (1 + 2z/h)$

$F_p = 0.524 W_p$

ASCE Section 13.3.1 & ASCE Equation 13.3-2

$F_{p,max} = 1.6 S_{DS} I_p W_p$

$F_{p,max} = 1.222 W_p$

ASCE Section 13.3.1 & ASCE Equation 13.3-3

$F_{p,min} = 0.3 S_{DS} I_p W_p$

$F_{p,min} = 0.229 W_p$

**SEISMIC DESIGN FORCES (ASD)**

ASCE Section 13.1.7 & 13.3.1

$F_{p,ASD} = 0.7 (F_{p,govern})$

$F_{p,ASD} = 0.366 W_p$

ASCE Section 13.1.7 & 13.3.1

$F_{p,v,ASD} = 0.7 (0.2 S_{DS} W_p)$

$F_{p,v} = 0.071 W_p$

**DESIGN FORCES**

① X-Ray

$W_t = 772^{\#}$

$F_p = 0.366(772^{\#}) = 283^{\#}$

$F_{p,v} = 0.071(772^{\#}) = 55^{\#}$

② Longitudinal Rails

$W_t = 118^{\#}$

$F_p = 0.366(118^{\#}) = 43^{\#}$

$F_{p,v} = 0.071(118^{\#}) = 8^{\#}$

$T_{\textcircled{1}} = \frac{283^{\#}(45'')(63'')}{4.6175(32'')(58'')} + \frac{(772^{\#} + 55^{\#})(63'')(28.7'')}{4.6175(58'')(32'')} = 310^{\#}/6.1t$

$T_{\textcircled{2}} = \frac{118^{\#} + 8^{\#}}{7(26.1t5)} = 9^{\#}/6.1t$

$T_u = 310^{\#}/6.1t + 9^{\#}/6.1t = \boxed{319^{\#}/6.1t}$

$V_{\textcircled{1}} = \frac{283^{\#}(28.7'')}{4.6175(32'')} = 63^{\#}/6.1t$

$V_{\textcircled{2}} = \frac{43^{\#}}{7(26.1t5)} = 3^{\#}/6.1t$

$V_v = 63^{\#}/6.1t + 3^{\#}/6.1t = \boxed{66^{\#}/6.1t}$

∴ Use 3/8" Bolts (A307)

$T_{all} = 2,485^{\#}$

$V_{all} = 1,325^{\#}$

### Unistrut Frame Check

$$(E) \text{ Equip Wt} = 825^* \text{ (including rails)}$$

$$(N) \text{ Equip Wt} = \overset{\text{unit}}{\downarrow} 772^* + \overset{\text{Rails}}{\downarrow} 118^* = 890^*$$

$$\begin{aligned} \% \text{ D.F.} &= 1 - \frac{890^*}{825^*} \\ &= 8\% \leq 10\% \end{aligned}$$

∴ Design of unistrut frame ok

### Check Anchorage of frame for $\Omega_o$

\* Max Shear

$$\begin{aligned} V &= \left( \frac{\overset{\text{unit to 1 side}}{\downarrow} 283^* + \overset{\text{perm}}{\downarrow} 43^*/2}{2 \text{ frames}} + \frac{\text{Ceiling seismic load}}{2 \text{ frames}} \right) \Omega \\ &= (152^* + 35^*) 2.5 \\ &= 468^* \end{aligned}$$

\* Max Tension

$$\begin{aligned} T &= \left( \overset{\text{see pg 12}}{\downarrow} 319^*/6 + (26 \text{ lts}) + 6 \text{ psf} (2') (3'+1') \right) \Omega_o + \overset{\text{Vertical Component from brace due to } V}{\downarrow} 468^* \\ &= (638^* + 48^*) 2.5 + 468^* \\ &= 2183^* \end{aligned}$$

∴ (E)  $\frac{5}{8}$ " HiTi KB-TZ's w/ 4" Eff Embed

$$\frac{468^*}{26 \text{ lts} (3162^*)} + \frac{2183^*}{26 \text{ lts} (1941^*)} = 0.64 \leq 1.2 \text{ ok}$$



# SIEMENS MEDICAL SOLUTIONS

(AXIOM LUMINOS dRF SYSTEM)  
3M FULLY SYNCHRONIZED BRIDGE  
AND X-RAY TUBE STAND

DES. J. ROBERSON

JOB NO. 35-1326

DATE 1/21/14

SHEET


1

OF 2 SHEETS

SHEETS

## SEISMIC ANCHORAGE

## CEILING MOUNTED



### NOTES:

- FORCES ARE DETERMINED PER 2013 CALIFORNIA BUILDING CODE AND ASCE 7-10 STRENGTH DESIGN IS USED.

HORIZONTAL FORCE ( $E_h$ ) =  $4.50 W_p$  ( $S_{Ds} = 2.5, a_p = 2.5, I_p = 1.5, R_p = 2.5, z/h \leq 1$ )

VERTICAL FORCE ( $E_v$ ) =  $0.50 W_p$

- CENTER OF GRAVITY (C.G.) AND WEIGHT ARE THE GOVERNING PARAMETERS FOR DESIGN. THESE CALCULATIONS ENCOMPASS ALL WEIGHTS UP TO THE MAXIMUM WEIGHT SHOWN.
- STRUCTURAL ENGINEER OF RECORD FOR THE BUILDING SHALL PROVIDE SUPPORT STRUCTURE DESIGNED TO SUPPORT WEIGHTS AND FORCES SHOWN IN COMBINATION WITH ALL OTHER LOADS THAT MAY BE PRESENT.





SIEMENS MEDICAL SOLUTIONS

(AXIOM LUMINOS dRF SYSTEM)  
3M FULLY SYNCHRONIZED BRIDGE  
AND X-RAY TUBE STAND

DES. J. ROBERSON

JOB NO. 35-1326

DATE 1/21/14


SHEET

2

OF 2 SHEETS

SEISMIC ANCHORAGE

CEILING MOUNTED



PLAN AT CEILING

LOADS:

SUSPENDED EQUIPMENT

WEIGHT = 772 LB

HORIZONTAL FORCE (E<sub>h</sub>) = 4.50 W<sub>p</sub> = 3474 LB

VERTICAL FORCE (E<sub>v</sub>) = 0.50 W<sub>p</sub> = 386 LB

LONGITUDINAL RAILS

WEIGHT = 118 LB

HORIZONTAL FORCE (E<sub>h</sub>) = 4.50 W<sub>p</sub> = 531 LB

VERTICAL FORCE (E<sub>v</sub>) = 0.50 W<sub>p</sub> = 59 LB

BOLT FORCES:

TENSION (T)

$$T_{u1} = \frac{3474\#(45\")(64\")} {4 \text{ BOLTS } (32\")(59\")} + \frac{(772\#(12) + 386\#)(64\")(28.7\")} {4 \text{ BOLTS } (59\")(32\")} = 1644 \text{ LB/BOLT}$$

$$T_{u2} = \frac{118\#(12) + 59\#}{7(2 \text{ BOLTS})} = 14 \text{ LB/BOLT}$$


$$T_u = 1644\# + 14\# = 1658 \text{ LB/BOLT (MAX)}$$

SHEAR (V)

$$V_u = \frac{3474\#(28.7\")} {4 \text{ BOLTS } (32\")} + \frac{531\#}{7(2 \text{ BOLTS})} = 817 \text{ LB/BOLT (MAX)}$$



**2013 CBC & ASCE 7-10 EQUIPMENT ANCHORAGE FORCES - REMOTE TABLE - 9/A070**



Height, H = -  
 Height to center of gravity, Y = 29.0 in  
 Length, L = 47.0 in  
 Width, W = 22.5 in  
 Overturning Dimension, ω = 22.5 in  
 x = 11.3 in  
 y = 23.5 in  
 Weight, W<sub>p</sub> = 3241 lbs  
 # of anchors in shear = 6  
 # of anchors in tension = 2  
 Average roof height, h = 28 ft  
 Height of component attachment with respect to grade, z = 0 ft

**Seismic**

Seismic design requirements for equipment are based on ASCE 7-10, Chapter 13.

**COMPONENT AMPLIFICATION FACTOR**

ASCE Section 13.5, 13.6 & ASCE Table 13.5-1, 13.6-1

$a_p = 1.0$

**COMPONENT RESPONSE MODIFICATION FACTOR**

ASCE Section 13.5, 13.6 & ASCE Table 13.5-1, 13.6-1

$R_p = 2.5$

**DESIGN SPECTRAL RESPONSE ACCELERATION**

CBC Section 1613A.5.4 & CBC Equation 16-39

$S_{DS} = 0.509$

**COMPONENT IMPORTANCE FACTOR**

ASCE Section 13.1.3

$I_p = 1.50$

**ATTACHMENT FACTOR IN CONCRETE OR MASONRY**

ASCE Section 13.4.2.1 and ACI 318-10 sec D3.3.4.3 d

$\Omega \text{ factor} = 2.5$

**SEISMIC DESIGN FORCE**

ASCE Section 13.3.1 & ASCE Equation 13.3-1

$F_p = 0.4a_p S_{DS} W_p / (R_p / I_p) (1 + 2z/h)$

$F_p = 0.122 W_p$

ASCE Section 13.3.1 & ASCE Equation 13.3-2

$F_{p,max} = 1.6 S_{DS} I_p W_p$

$F_{p,max} = 1.222 W_p$

ASCE Section 13.3.1 & ASCE Equation 13.3-3

$F_{p,min} = 0.3 S_{DS} I_p W_p$

$F_{p,min} = 0.229 W_p$

**SEISMIC DESIGN FORCES (ASD)**

ASCE Section 13.1.7 & 13.3.1

$F_{p,ASD} = 0.7 (F_{p,govern})$

$F_{p,ASD} = 0.160 W_p$

ASCE Section 13.1.7 & 13.3.1

$F_{pv,ASD} = 0.7 (0.2 S_{DS} W_p)$

$F_{p,v} = 0.071 W_p$

**DESIGN FORCES**

$F_{p,ASD} = 520 \text{ lbs}$

$OTM = Y * F_{p,ASD} = 15070 \text{ lb-in}$

$F_{p,v} = 231 \text{ lbs}$

$DLRM = (0.6W_p - F_{pv}) * x = 0 \text{ lb-in}$

$T = \frac{(OTM - DLRM) * \Omega \text{ factor}}{\omega * (\# \text{ Anchors})}$

$T = 837 \text{ lbs}$

$V = \frac{2 (F_{p,ASD} * (y / L)) * \Omega \text{ factor}}{\# \text{ Anchors}}$

$V = 217 \text{ lbs}$

(V is approximate when number of anchors exceeds 4)

**USE (6)-5/8"Ø HILTI KB-TZ's W/ 4" EFFECTIVE EMBEDMENT**

$T_{ALL} = 3113 \text{ lbs}$

$V_{ALL} = 3119 \text{ lbs}$

UNITY CHECK = 0.39

## SIEMENS MEDICAL SOLUTIONS

(AXIOM LUMINOS dRF SYSTEM)

## LUMINOS dRF REMOTE TABLE

DES. **J. ROBERSON**

JOB NO. **35-1326**

DATE **1/22/14**

SHEET


**1**

OF **2**

SHEETS

SEISMIC ANCHORAGE

CONCRETE SLAB



NOTES:

- FORCES ARE DETERMINED PER 2013 CALIFORNIA BUILDING CODE AND ASCE 7-10 STRENGTH DESIGN IS USED.

HORIZONTAL FORCE (E<sub>h</sub>) = 0.855 W<sub>p</sub> (S<sub>Ds</sub> = 1.90, a<sub>p</sub> = 1.0, I<sub>p</sub> = 1.5, R<sub>p</sub> = 1.5, Ω<sub>o</sub> = 1.5, z/h = 0)

HORIZONTAL FORCE (E<sub>hc</sub>) = 1.28 W<sub>p</sub> (Ω<sub>o</sub> = 1.5 FOR CONCRETE ANCHORAGE)

VERTICAL FORCE (E<sub>v</sub>) = 0.38 W<sub>p</sub>

- CENTER OF GRAVITY (C.G.) AND WEIGHT ARE THE GOVERNING PARAMETERS FOR DESIGN. THESE CALCULATIONS ENCOMPASS ALL WEIGHTS UP TO THE MAXIMUM WEIGHT SHOWN.
- STRUCTURAL ENGINEER OF RECORD FOR THE BUILDING SHALL PROVIDE SUPPORT STRUCTURE DESIGNED TO SUPPORT WEIGHTS AND FORCES SHOWN IN COMBINATION WITH ALL OTHER LOADS THAT MAY BE PRESENT.



## SIEMENS MEDICAL SOLUTIONS

(AXIOM LUMINOS dRF SYSTEM)

## LUMINOS dRF REMOTE TABLE

DES. J. ROBERSON

JOB NO. 35-1326

DATE 1/22/14


SHEET

2

OF 2 SHEETS

SEISMIC ANCHORAGE

CONCRETE SLAB



**PLAN AT BASE**

LOADS: PER 2013 CALIFORNIA BUILDING CODE AND ASCE 7-10.

(STRENGTH DESIGN IS USED) ( $S_{Ds} = 1.90$ ,  $a_p = 1.0$ ,  $I_p = 1.5$ ,  $R_p = 1.5$ ,  $\Omega_o = 1.5$ ,  $z/h = 0$ )

WEIGHT = 3241 LB

HORIZONTAL FORCE ( $E_{hd}$ ) =  $1.28 W_p = 4148$  LB

VERTICAL FORCE ( $E_v$ ) =  $0.38 W_p = 1232$  LB

BOLT GROUP PROPERTIES:

$$I_{X-X} = 768 \text{ in}^4$$

$$I_{Z-Z} = 2186 \text{ in}^4$$

$$I_{Y-Y} = 2954 \text{ in}^4$$

MOMENTS:

$$M_{XX} = 4148\#(29") + (1.2(3241\#) + 1232\#)(11.813") = 180,795\#\$$

$$M_{ZZ} = 4148\#(29") = 120,306\#\$$

$$M_{YY} = 4148\#(11.8125") = 49,004\#\$$

BOLT SPECS: 5/8"  $\phi$  HILTI KB-TZ

$$\phi T = 0.75 \phi N_n = 3329 \text{ LB/BOLT (TENSION)}$$

$$\phi V = \phi V_n = 4940 \text{ LB/BOLT (SHEAR)}$$

BOLT FORCES:

TENSION (T)

$$T_{U \text{ MAXIMUM}} = \left[ \frac{120306\#(23.375")}{2186} \times (0.3) \right] + \frac{180795\#(11.3125")}{768} = 3049 \text{ LB/BOLT (MAX)}$$

SHEAR (V)

$$V_{U \text{ MAXIMUM}} = \frac{4148\#}{6 \text{ BOLTS}} + \frac{49004\#(25.97")}{2954} = 1122 \text{ LB/BOLT (MAX)}$$



# APPLICATION FOR PREAPPROVAL SPECIAL SEISMIC CERTIFICATION OF EQUIPMENT AND COMPONENTS

For Office Use Only

<b>APPLICATION NO.</b>
<b>OSP – 0086-10</b>

Check whether application is: NEW  RENEWAL

**SIEMENS MEDICAL SOLUTIONS USA, INC.**

Steven B. Wagman

1.0

Manufacturer

Manufacturer's Technical Representative

51 Valley Stream Parkway, Malvern, PA. 19355

Mailing Address

(610) 219-2137

Telephone

Steven.wagman@siemens.com

E-mail Address

2.0

Axiom Luminos dRF & Axiom Luminos TF R/F Systems

Product Name

Radiography & Fluoroscopy (R/F) imaging systems

Product Type

**SEE ATTACHMENT 1**

Product model No (List all unique product identification numbers and/or serial numbers)

General Description: Multi-component radiography & fluoroscopy systems used for medical imaging.

3.0

**EQUIPMENTANCHORAGE.COM**

Applicant Company Name

JONATHAN ROBERSON, S.E.

Contact Person

5877 Pine Ave, Suite 210, Chino Hills, CA. 91709

Mailing Address

(406) 541-EASE (3273)

Telephone

jon@easeco.com

E-mail Address

I hereby agree to reimburse the Office of Statewide Health Planning and Development for the actual costs incurred by the department for review.

Signature of Applicant  
 SENIOR ENGINEER  
 Title

June 18, 2010

Date

**EQUIPMENTANCHORAGE.COM**

Company Name



Registered Design Professional Preparing the Report

4.0

EQUIPMENTANCHORAGE.COM

Company Name

Jonathan Roberson, S.E.

S4197

Contact Name

California License Number

5877 Pine Ave, Suite 210, Chino Hills, CA. 91709

Mailing Address

909-606-7622

jon@easeco.com

Telephone

E-mail Address

California Licensed Structural Engineer Review and Acceptance of the Report

5.0

EQUIPMENTANCHORAGE.COM

Company Name

Jonathan Roberson, S.E.

S4197

Contact Name

California License Number

5877 Pine Ave, Suite 210, Chino Hills, CA. 91709

Mailing Address

909-606-7622

jon@easeco.com

Telephone

E-mail Address

Anchorage Pre-Approval

6.0

- Anchorage is pre-approved under OPA- (Separate application for anchorage pre-approval is required)
Anchorage is not Pre-approved

Certification Method

7.0

- Testing in accordance with: ICC-ES AC-156
Other (Please Specify):
Analysis
Experience data
Combination of Testing, Analysis, and/or Experience Data (Please Specify):

Testing Laboratory (if applicable)

8.0

Environmental Testing Laboratory, Inc.

Brady Richard

Company Name

Contact Name

11034 Indian Trail, Dallas, TX 75229-3513

Mailing Address

972-247-9657

brady@etldallas.com

Telephone

E-mail



Approval Parameters

9.0

Design in accordance with ASCE 7-05 Chapter 13:  Yes  No

Design Basis of Equipment or Components ( $F_p/W_p$ ) = 2.4g

- $S_{DS}$  (Spectral response acceleration at short period) = 2.00
- $a_p$  (In-structure equipment or component amplification factor) = 1.0
- $R_p$  (Equipment or component response modification factor) = 1.5
- $I_p$  (Importance factor) = 1.5
- $z/h$  (Height factor ratio) = 1.0
- Equipment or Component fundamental frequency(s) = SEE ATTACHMENT 1
- Building period limits (if any) = NO LIMIT
- Overall dimensions and weight (or range thereof) = SEE ATTACHMENT 1

Equipment or Components @ grade designed in accordance with ASCE 7-05 Chapter 15:  Yes  No


Design Basis of Equipment or Components ( $VW$ ) =

- $S_{DS}$  (Spectral response acceleration at short period) =
- $S_1$  (Spectral response acceleration at 1 second period) =
- $R$  (Response modification coefficient) = 1.0
- $\Omega_0$  (System overstrength factor) = 1.0
- $C_d$  (Deflection amplification factor) = 1.0
- $I_p$  (Importance factor) = 1.5
- Height to Center of Gravity above base =
- Equipment or Component fundamental period(s) = Sec
- Overall dimensions and weight (or range thereof) =

Tank(s) designed in accordance with ASME BPVC, 2007:  Yes  No

10.0 List of attachments supporting the special seismic certification of equipment or components:

- Test Report
- Drawings
- Manufacturer's Catalog
- Calculations
- Others (Please Specify): SE Acceptance Letter, Attachment 1

<b>11.0 OSHPD Approval (For Office Use Only)</b>	
 Signature & Date <b>Chris Tokas, SHFR</b> Name & Title	9/20/10 December 31, 2016 Approval Expiration Date $S_{CS}$ (g) = 2.0 $z/h$ = 1.0 Special Seismic Certification Valid Up to
Condition of Approval (if any):	

## APPLICATION FOR PREAPPROVAL SPECIAL SEISMIC CERTIFICATION OF EQUIPMENT AND COMPONENTS

### ATTACHMENT 1: Seismically Certified Components

Description	Width (in.)	Depth (in.)	Height (in.)	Weight (lb.)	Mount <sup>CDEF</sup>	Lowest Resonant Freq. (Hz.) <sup>A</sup>		
						F/B	S/S	Vert.
<b>AXIOM LUMINOS dRF RADIOGRAPHY &amp; FLUOROSCOPY SYSTEM</b>								
X-Ray Tube w/3M Bridge	120	126	106	754	Ceiling Suspension	13.9	4.4	14.6
Wall Stand	28	28	82	617	Floor Mount	8.9	7.6	8.7
Luminos dRF Table	83	75	107	2892	Floor Mount	4.6	4.8	4.6
Flourosport Compact	13.5	27.5	21.75	108	Floor Mount	23.3	11.8	>50
Polydoros F80 63kW-80kW Generator Cabinet	31.5	17.25	86.5	826	Wall/Floor	10.1	11.2	31.0
DCS-1 Display Ceiling Suspension	168	28	102	290	Ceiling Suspension	8.0	6.4	14.8
Luminos dRF Control Console	---	---	---	---	Countertop	--- <sup>B</sup>	--- <sup>B</sup>	--- <sup>B</sup>
19" Monitor Desktop Stand	---	---	---	---	Countertop	--- <sup>B</sup>	--- <sup>B</sup>	--- <sup>B</sup>
Keyboard & Mouse	---	---	---	---	Countertop	--- <sup>B</sup>	--- <sup>B</sup>	--- <sup>B</sup>
Foot Pedal	---	---	---	---	Countertop	--- <sup>B</sup>	--- <sup>B</sup>	--- <sup>B</sup>
<b>AXIOM LUMINOS TF RADIOGRAPHY &amp; FLUOROSCOPY SYSTEM</b>								
3D TOP w/4M Bridge	167	119	38	819	Ceiling Suspension	10.5	6.4	5.0
Luminos TF Table	83	72	77.9	3910	Floor Mount	5.3	4.1	4.3
Cable Drop Box	10.75	8.25	7	161	Wall	13.6	10.3	6.3
DCS 2 Display Ceiling Suspension	167	48	63	440	Ceiling Suspension	10.3	7.7	4.0
Fluorospot Compact Container	17.75	26	23	172	Floor Mount	26.1	9.7	30.4
Polydoros SX 65/80 Generator Cabinet	31.5	17.25	84	641	Wall/Floor	7.9	8.3	20.0
System Cabinet	23.25	17.125	84	518	Wall/Floor	7.9	8.3	19.0
Vertex MT Wall Stand	32	26.75	88.25	416	Floor Mount	9.8	7.9	7.3
Vertex MT Wall Stand	32	26.75	88.25	416	Wall/Floor	---	---	---
Keyboard, Mouse & Monitor	18.3	9.5	17.5	20	Countertop	--- <sup>B</sup>	--- <sup>B</sup>	--- <sup>B</sup>
Control Console	9.25	10.25	2.75	10	Countertop	--- <sup>B</sup>	--- <sup>B</sup>	--- <sup>B</sup>

**Notes:**

- A) F/B = Front-to-Back Axis; S/S = Side-to-Side Axis; Vert. = Vertical Axis
- B) Not monitored
- C) "Floor Mounted" refers to a free-standing, floor-mounted condition.
- D) "Wall/Floor" indicates a condition where the unit bears on, and is anchored directly to the supporting floor. In addition, lateral restraint anchoring the unit to an adjacent wall or other supporting structure is provided at the top of the equipment.
- E) "Ceiling Suspended" refers to a condition where the unit is anchored to and suspended from a framing system at or slightly above the ceiling line of the room.
- F) "Countertop" refers to a condition where the unit sits atop but is not otherwise anchored to a counter, desk, or other piece of fixed furniture.

Hilti Kwik Bolt TZ - Slab on Grade

$f_c = 3000$  psi

Conversion Factor = 1.40

ACI 318-08 D3.3.3 Reduction Factor = 0.75

Nominal Anchor Diameter (in)	Effective Embedment $h_{ef}$ (in)	Min. Edge Distance $C_{at}$ (in)	Critical Edge Distance $C_{ac}$ (in)	Min. Member Thickness (in)	Tension												Allowable Seismic Tension (lbs)
					Steel Strength			Pullout Strength			Concrete Breakout Strength						
					$N_{sa}$ (lbs)	$\Phi$	$\Phi N_{sa}$ (lbs)	$N_{p,cr}$ (lbs)	$\Phi$	$\Phi N_{pn}$ (lbs)	$K_c$	$N_{cb}$ (lbs)	$\Phi$	$\Phi N_{cb}$ (lbs)			
0.375	2.00	4.38	4.38	4.00	6,500	0.75	4,875	2,270	0.65	1,616	17	2,634	0.65	1,712	1,039		
0.500	2.00	5.50	5.50	4.00	10,705	0.75	8,029	4,915	0.65	3,500	17	2,634	0.65	1,712	1,100		
0.500	3.25	7.50	7.50	6.00	10,705	0.75	8,029	4,915	0.65	3,500	17	5,456	0.65	3,546	2,250		
0.625	3.13	6.50	6.50	5.00	17,170	0.75	12,878				17	5,144	0.65	3,343	2,149		
0.625	4.00	8.75	8.75	6.00	17,170	0.75	12,878				17	7,449	0.65	4,842	3,113		
0.750	3.75	10.00	10.00	6.00	25,120	0.75	18,840				17	6,762	0.65	4,395	2,825		
0.750	4.75	9.00	9.00	8.00	25,120	0.75	18,840				17	9,639	0.65	6,266	4,028		

Shear														
Steel Strength				Concrete Breakout Strength						Pryout Strength				Allowable Seismic Shear (lbs)
$V_{sa,eq}$ (lbs)	$\Phi$	$\Phi V_{sa}$ (lbs)	$A_{vc}$ (in <sup>2</sup> )	$A_{vc0}$ (in <sup>2</sup> )	$V_b$ (lbs)	$V_{cb}$ (lbs)	$\Phi$	$\Phi V_{cb}$ (lbs)	$N_{cb}$ (lbs)	$K_p$	$V_{cp}$ (lbs)	$\Phi$	$\Phi V_{cp}$ (lbs)	
2,255	0.65	1,466	53	86	3,003	1,830	0.7	1,281	2,634	1	2,634	0.7	1,844	1,098
5,495	0.65	3,572	66	136	4,614	2,237	0.7	1,566	2,634	1	2,634	0.7	1,844	1,342
5,495	0.65	3,572	135	253	8,097	4,318	0.7	3,023	5,456	2	10,911	0.7	7,638	2,591
7,600	0.65	4,940	98	190	6,930	3,554	0.7	2,488	5,144	2	10,288	0.7	7,201	2,132
7,600	0.65	4,940	158	345	11,372	5,199	0.7	3,639	7,449	2	14,898	0.7	10,429	3,119
11,745	0.65	7,634	180	450	14,487	5,795	0.7	4,056	6,762	2	13,523	0.7	9,466	3,477
11,745	0.65	7,634	216	365	12,968	7,685	0.7	5,379	9,639	2	19,279	0.7	13,495	4,611

**Hilti Kwik Bolt TZ - Deck Underside**

$f_c = 3000$  psi

Conversion Factor = 1.40

ACI 318-08 D3.3.3 Reduction Factor = 0.75

Nominal Anchor Diameter (in)	Effective Embedment $h_{ef}$ (in)	Tension				Shear			
		Pullout Strength		Allowable Seismic Tension (lbs)	Steel Strength		Allowable Seismic Shear (lbs)		
		$N_{p,deck,cr}$ (lbs)	$\Phi$		$V_{sa,deck,eq}$ (lbs)	$\Phi$			
0.375	2.00	1,460	0.65	610	1,340	0.65	871	747	
0.500	2.00	1,460	0.65	610	3,000	0.65	1,950	1,671	
0.500	3.25	2,620	0.65	1,095	4,945	0.65	3,214	2,755	
0.625	3.13	2,000	0.65	836	4,320	0.65	2,808	2,407	
0.625	4.00	4,645	0.65	1,941	5,675	0.65	3,689	3,162	